Public Record – Summary Information for Regulated Underground Storage Tanks (USTs) Navajo Nation Environmental Protection Agency – Storage Tank Program

Date Posted to Web: January 4, 2023

General Information: Total Number of UST Facilities: 97


Total Number of USTs: 249

Summary of Information for On-site Inspections:

Number of UST Facilities Inspected 51

Inspection Period Dates: October 1, 2021 – September 30, 2022

Percent Compliance (SOC Combined measure): 41%



Note: The COVID-19 Pandemic impacted the program by limiting the number of inspections and follow-up necessary to ensure the facilities are in compliance with the Navajo Nation Storage Tank Act of 2012. Tank, facility, and on-site inspection information is based on financial responsibility, release detection tests, applicable documentation and verification of release prevention equipment. On-site inspections measure compliance with release detection and release prevention requirements with Subtitle I 40 CFR 280.12 and the Navajo Nation Storage Tank Act of 2012.

Summary Information of Release:

Number of Confirmed Releases: 0

Release Reporting Period Dates: October 1, 2021 - September 30, 2022

Summary Information for Release Sources and Causes:

			Cause														
							Phys/Mech										
Source			Spill		Overfill		Damage		Corrosion		Install Problem		Other		Unknown		
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%	
Tank	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Piping	1	2	0	0	0	0	0	0	1	2	0	0	0	0	0	0	
Dispenser	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
STP	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Delivery Problem	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Other	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Unknown	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Totals	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
# = number, % = per	cent of to	otal num	ber														

Note: Release, sources and cause information is based on release detection/prevention data to verify the necessary tests were performed on the system and verification of equipment operability. Source and cause data were collected using techniques such as reviewing release detection/prevention documentation provided by the facility and by visually inspecting the equipment.

For more information on site-specific UST information on compliance and releases, please submit your written request to:

Navajo Nation Environmental Protection Agency
Waste Regulatory Compliance Department
Storage Tank Program
Post Office Box 3089
Window Rock, Arizona 86515